

ANDHRA PRADESH POWER GENERATION CORPORATION LTD
VIDYUT SOUDHA :: VIJAYAWADA - 520004
Day wise Generation Particulars as on 16-7-2026

Station	Unit	Capacity (MW)	Daywise Generation in MU			1st to 16th Jul Monthly Gen		1st Apr to 16th Jul (107 days) FY Cum Gen	
			16 Jul 2026	15 Jul 2026	14 Jul 2026	Gen (MU)	PLF (%)	Gen (MU)	PLF (%)
A. Thermal Power Generation									
Dr.Narla Tatarao TPS Vijayawada	Unit 1	210.00	3.54	3.55	3.53	47.53	58.94	352.72	65.41
	Unit 2	210.00	3.65	3.71	3.69	51.10	63.37	322.70	59.84
	Unit 3	210.00	3.88	3.85	3.73	59.08	73.26	399.41	74.06
	Unit 4	210.00	4.16	4.01	3.96	59.58	73.88	417.63	77.44
	Unit 5	210.00	–	–	–	18.96	23.51	317.46	58.87
	Unit 6	210.00	4.10	3.87	3.70	52.72	65.38	317.86	58.94
	Unit 7	500.00	10.94	9.86	9.57	139.57	72.69	941.50	73.33
	Unit 8	800.00	15.33	15.22	16.23	229.44	74.69	1,471.26	71.62
	Station	2,560.00	45.60	44.07	44.41	657.98	66.93	4,540.54	69.07
Rayalaseema TPP	Unit 1	210.00	4.17	3.95	3.86	53.61	66.48	339.74	63.00
	Unit 2	210.00	4.39	4.22	4.06	41.33	51.25	335.00	62.12
	Unit 3	210.00	0.00	0.00	0.00	0.00	0.00	304.45	56.45
	Unit 4	210.00	4.43	1.56	3.91	43.76	54.27	349.27	64.77
	Unit 5	210.00	4.12	3.94	3.74	41.17	51.05	355.96	66.01
	Unit 6	600.00	10.73	9.94	9.83	146.76	63.70	1,067.14	69.26
	Station	1,650.00	27.84	23.61	25.40	326.63	51.55	2,751.56	64.94
APGENCO THERMAL		4,210.00	73.44	67.68	69.81	984.61	60.90	7,292.10	67.45
B. Hydel Power Generation									
Machkund (AP Utilisation)		60.00	–	–	–	0.00	–	0.00	–
Tungabhadra (AP Utilisation)		57.60	0.01	0.00	0.00	0.14	–	7.28	–
Upper Sileru		240.00	1.23	1.26	2.13	31.46	–	181.41	–
Donkarayi		25.00	0.46	0.47	0.47	6.37	–	12.63	–
Lower Sileru		460.00	3.36	3.86	3.55	50.89	–	371.78	–
Srisaïlam Right		770.00	0.00	0.00	0.00	0.15	–	4.74	–
NS Right Canal		90.00	0.00	0.00	0.00	0.00	–	2.03	–
NSTPHES		50.00	0.00	0.00	0.00	0.00	–	2.74	–
Penna Ahobilam		20.00	0.00	0.00	0.00	0.00	–	0.00	–
Chettipeta		1.00	–	–	–	0.00	–	0.00	–
APGENCO Hydro		1,773.60	5.06	5.59	6.15	89.01	–	582.61	–
C. Solar Power Generation									
Solar 5.4 MW		5.40	–	–	–	0.00	–	0.00	–
Solar 400 MW		400.00	1.36	2.17	2.06	23.82	–	136.49	–
APGENCO Solar		405.40	1.36	2.17	2.06	23.82	–	136.49	–
Total APGENCO		6,389.00	79.86	75.44	78.02	1,097.44	–	8,011.20	
Machkund Generation		120.00	–	–	–	0.00	–	129.80	–
TB Dam Generation		72.00	0.00	0.00	0.00	0.00	–	8.94	–
D. APPDCL									
SDSTPS	Stage-I	1,600.00	28.29	23.70	–	198.98	32.39	1,856.17	45.18
	Stage-II	800.00	16.79	16.25	16.11	243.07	79.12	1,242.00	60.46
Total SDSTPS	Station	2,400.00	45.08	39.95	16.11	442.05	47.97	3,098.17	50.27

Outage of Thermal Units

Outage of Hydel Units

Outage of Solar Units

[illegible][illegible]

Reservoir Levels, Storages and Equivalent Energy on 16-July											
Reservoir	FRL (Ft.)	Storage at FRL(TMCFt)	MDDL (Ft)	16-Jul-2026				16-Jul-2025			
				Level (Ft)	Storage (TMCft)		Eqv. Energy (MU)	Level (Ft)	Storage (TMCft)		Eqv. Energy (MU)
					Gross	Live			Gross	Live	
Jalaput	2,750.00	34.30	2,685.00	–	–	–	–	2,735.80	31.52	19.96	319.36
Balimela	1,516.00	127.50	1,440.00	1,456.40	46.14	13.14	121.04	1,463.40	52.61	19.61	180.66
Guntawada	1,360.00	4.33	1,333.50	1,341.00	1.31	0.60	3.43	1,343.10	1.53	0.82	4.66
Donkarayi	1,037.00	17.40	955.00	1,033.70	15.55	7,428.02	146.56	999.70	8.22	4.98	59.30
Total Sileru Basin					63.00	7,441.76	271.03		93.88	45.37	563.98
Tungabhadra	1,633.00	100.90	1,582.00	1,603.32	26.12	–	–	1,626.06	80.00	–	–
Srisaïlam	885.00	215.80	800.00	821.20	41.70	12.70	71.23	881.80	197.90	168.90	946.02
Nagarjunasagar	590.00	312.00	510.00	513.60	137.86	0.00	0.00	559.00	230.06	61.92	60.00
NSTPD	247.70	7.10	242.80	247.41	7.02	0.94	1.37	247.47	7.03	0.95	1.39
Total Krishna Basin	–	–	–		212.70	13.64	72.60		514.99	231.77	1,007.41